

DW WINDSOR 'RIGA' BOLLARD With anodised louvre - no backshield

Lamp: 42W PL-T

Isolation unit: Charles Manufacturing Ltd. LSI 02 or similar approved.

Colour: PAN 7621

Bracknell

Council

Reference: RIB A 042P 81 N

Project Drawing No. SD/1300/07 STANDARD DRAWINGS Scale NOT TO SCALE Department of Environment, STREET LIGHTING BOLLARD

Drawing Number

Director.

2. Fuse discrimination must be applied.

4. Isolator to be phase identified.

Do not scale this drawing

Checked

Date Mar 11

Culture & Communities

Rev Date

insulated colour code green/yellow.

Notes

1300/07

All electrical equipment must be to the approval of the

Size of earth conductor from column earth bolt to door to be 4mm sq. copper 56/0.30 flexible cord PVC

To be used in residential areas only at the discretion of

All terminations to be made using crimped lugs.