



- Notes
1. Construction to be to the approval of the Overseeing Organisation.
 2. Bituminous materials to be to BS EN 13108 & BS 594987.

CONSTRUCTION TYPE 1

- 25mm Surface course – AC6 close surf 100/150
- 70mm Binder course – AC20 dense bin 100/150
- 100mm Base – AC32 HDM base 40/60
- 250mm Granular sub-base material Type 1

CONSTRUCTION TYPE 2

- 30mm Surface course – AC10 close surf 100/150
- 70mm Binder course – AC20 dense bin 100/150
- 130mm Base – AC32 HDM base 40/60
- 220mm Granular sub-base material Type 1

CONSTRUCTION TYPE 3

- 40mm Surface course – HRA 30/14 F surf 40/60 PSV⁵⁰
- 60mm Binder course – AC20 dense bin 100/150
- 130mm Base – AC32 HDM base 40/60
- 220mm Granular sub-base material Type 1

Do not scale this drawing

Rev	Date	Description	Checked
C	APR 19	Updated title block	NR
B	MAR 11	Amendment to BS/EN standards	KPT
A	JAN 08	Various minor amendments	KPT



Project
STANDARD DRAWINGS

Title
CARRIAGEWAY HAUNCHING

Drawing No.
SD/700/05C

Scale NOT TO SCALE Date MAY 04

Department of Place,
Planning & Regeneration